

LOCATION	731 Carlton Dr.			CITY			Boston
BETWEEN	Garrison Blvd.			STREET &			Graystone
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED	
MAIN TO BLDG.	3/4	P	6'	5-21-94	Tied over	125' Existing	
MAIN TO PROP. LINE					3/4 CW!		
PROP. LINE TO BLDG.							

ENTERS: 731 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 170' N of C of Garrison Blvd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 19' W of C of Carlton Dr. — Carlton Dr.

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS: Tied Tracer wire off at Tee.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser 731 - 5
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY

Riser 10-13-94
.85