

LOCATION 113 CARMEL HILLS DR CITY GASTONIA

BETWEEN PATRICK RD STREET & CAPELLA CT STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>78</u>	<u>7-24-96</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>8</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>20</u>			

ENTERS: 113 BRANCHED INTO: \_\_\_\_\_

TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 110' W OF C OF PATRICK RD


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SP

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC C YEAR INSTALLED 1995

DEPTH: 3 FT. 6 IN. LOCATION 16' S OF C OF CARMEL HILLS DR

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # 00397122

REMARKS: \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY