

LOCATION 302 Carmel Hills Dr. CITY GASTONIA
BETWEEN SEAQUAY Ct. STREET & WARTON Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>98'</u>	<u>6-7-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>44'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>54'</u>			

ENTERS: 302

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 119' W of Coy WARTON Ct.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 15' S of Coy Carmel Hills Dr.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 L.R. # 291825

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY