

LOCATION 410 Carmel Hills Dr CITY Gastonia

BETWEEN Blackburn Ct. STREET @ Sneyum Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	405'	9-27-96		
MAIN TO PROP. LINE	3/4"	P	40'			
PROP. LINE TO BLDG.	3/4"	P	365'			

ENTERS: 410 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 94' NE of center of Blackburn Ct


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. H. H. H. H.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH: 3 Ft. 0 In. LOCATION 12' SE. of center of Carmel Hills Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 536994

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY