

LOCATION 307 Carolina Ave. CITY Castroville

BETWEEN Jewett St STREET & Westview St STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|----------|------------|---------------|---------|---------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>64'</u> | <u>1-5-98</u> | | |
| MAIN TO PROP. LINE | <u>3/4"</u> | <u>P</u> | <u>4'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>60'</u> | | | |

ENTERS: 307 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 219' W. of center of

Jewett St


PRESSURE TEST: @ 160 PSI FOR 1/4 HRS. BY S. Guffey

MAIN-SIZE 3" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION 25' S. of center of Carolina Ave

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 873327

REMARKS:



| Test Station | | |
|--|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY