

LOCATION 503 Carolina Ave

CITY Corstensa

BETWEEN S. York Rd.

STREET & Florida

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>	<u>Tied over 153' of Ext 3/4</u>		
MAIN TO PROP. LINE				<u>Plastic to Ext 2" Plastic Main</u>		
PROP. LINE TO BLDG.				<u>2-9-98</u>		

ENTERS: 503

BRANCHED INTO: 0

TAP SIZE: <u>1/2</u>	PRESSURE <u>60</u> PSI	INCHES W C	LOCATION
----------------------	------------------------	------------	----------


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY EP

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 3 FT 6 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# 17 # L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY