

LOCATION 508 Carolina Ave.

CITY GASTONIA

BETWEEN York Rd.

STREET &amp; Florida St

STREET

	SIZE	TYPE	LENGTH	INSTALLED <del>REMOVED</del> Retired	RETIRED	RENEWED
MAIN TO BLDG.	1"	Bare		10-19-93	72" Existing	
MAIN TO PROP. LINE					1" Bare Service	
PROP. LINE TO BLDG.						

ENTERS: 508

BRANCHED INTO: 0

TAP SIZE: 3/8

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

205' E of Cor York Rd.


PRESSURE TEST: @ \_\_\_\_\_ psi For \_\_\_\_\_ Hrs. By \_\_\_\_\_

SERVICE  
MAIN SIZE 1" C.I. \_\_\_\_\_ BARE STEEL ☒ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_

DEPTH: \_\_\_\_\_ Ft. \_\_\_\_\_ In. LOCATION \_\_\_\_\_

"A" P/S READING .05 TOTAL ANODES 1\* 1 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: Retired Bare Service, Removed 1" Bare Riser P.S. .05 Installed 1 lb. Anodes



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY