

LOCATION 601 CARDINA AveCITY GASTONBETWEEN FloridaSTREET & Jackson

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>26'</u>			<u>2-5-98</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>21'</u>			


ENTERS: 601BRANCHED INTO: ✓TAP SIZE: 3/4PRESSURE 60 PSI

INCHES WC

LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY SEMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997DEPTH: 3 FT. 0 IN. LOCATION"A" P/S READING PHTOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY