

LOCATION 607-609-611 CAROLINA Ave CITY Gaston

BETWEEN Florida ST STREET &amp; STREET

	SIZE	TYPE	LENGTH	Tie over	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	298	2/7/98		
MAIN TO PROP. LINE	3/4					
PROP. LINE TO BLDG.	3/4					

ENTERS: 607-609-611

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION West side of 607  
South side of 609  
West side of 611


PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY DJ

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1992

DEPTH: 3 FT 0 IN. LOCATION South side of Carolina Ave

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. #

REMARKS: 95' OF EX 3/4" Plastic service tied to New main - 607  
79' OF EX 3/4" Plastic service tied to New main - 609  
124' OF EX 3/4" Plastic service tied to New main 611  
TOTAL 298 (Service to 609 split with service to 607.)  
(Service to 611 split with service to 609)



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY