


LOCATION 614 4622 CAROLINA AVE CITY GASTONIABETWEEN Florida Ave STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	120'	2/7/88		
MAIN TO PROP. LINE	3/4"		55			
PROP. LINE TO BLDG.	3/4"		65'			

ENTERS: 614 BRANCHED INTO:TAP SIZE: 3/4 PRESSURE 60 PSI INCHES W.C. LOCATION West side of 614PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY DTMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1992DEPTH: 3 FT 0 IN. LOCATION South side of Carolina Ave"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. #REMARKS: Tied over service to 622 to new main. Service to 622 split with  
Service to 614. See w# 071545 for Retirement of Service

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY