

LOCATION 617 Carolina Ave CITY Crofton  
BETWEEN JACKSON Rd STREET & Florida Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>2'</u>		<u>Tied over</u>	<u>44' of</u>
MAIN TO PROP. LINE				<u>10-12-94</u>	<u>Ext 3/4</u>	<u>for Service</u>
PROP. LINE TO BLDG.					<u>over to Ext 3/4</u>	<u>plastic</u>

ENTERS: 615 BRANCHED INTO: 617

TAP SIZE: 3/4 ser PRESSURE 20 P.S.I. INCHES W.C. LOCATION

PRESSURE TEST: @ 100 psi For 114 Hrs. By LP


MAIN-SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 1 Ft. 6 In. LOCATION

"A" P/S READING P TOTAL ANODES 1\* 17\* L.R. #

REMARKS:

TAPER wire tied off AT Tee



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY