

LOCATION 630 & 634 CAROLINE AVE CITY Pastoria
BETWEEN FLORIDA STREET JACKSON STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>60'</u>	<u>2-7-98</u>	<u>tied over</u>	<u>23' 3/4 P.</u>
MAIN TO PROP. LINE					<u>Serv. to new</u>	<u>2" P</u>
PROP. LINE TO BLDG.					<u>main</u>	

ENTERS: 630 BRANCHED INTO: 634
TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 23' S. of C of
Caroline

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY JP KH
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998
DEPTH 3 FT. 0 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>BR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY