

LOCATION 712 Carolina CITY GASTONIA

BETWEEN JACKSON STREET & ST. MICHAELS STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>12'</u>	<u>Relocated</u>	<u>7-11-96</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 712 BRANCHED INTO: 0

TAP SIZE: 3/4 Ser. PRESSURE 20 PSI _____ INCHES W.C. LOCATION


PRESSURE TEST: @ 105 PSI FOR 1 1/4 HRS. BY EP

MAIN-SIZE 3/4 C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1957

DEPTH: 1 FT. 6 IN. LOCATION

"A" P/S READING 15 TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>0.125V</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY