

LOCATION 801 & 803 CAROLINA Ave. CITY DARTONIA
BETWEEN Central Ave. STREET & Edgefield STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>150'</u>	<u>3-7-98</u>	<u>177' Existing</u>	<u>3/4 Ctw To Be Retired</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>20'</u>		<u>w/main</u>	<u>Tied over 109'</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>130'</u>		<u>Existing</u>	<u>3/4 PLASTIC ON 803</u>


ENTERS: 801 BRANCHED INTO: 803
TAP SIZE: 1/2 PRESSURE 40 PSI _____ INCHES W.C. LOCATION 40' W of C of Central Ave.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH: 4 FT 0 IN. LOCATION 15' S of C of CAROLINA Ave.

"A" P/S READING PLASTIC W/A TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser's</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

ENG. DEPT. USE ONLY

801
&
803