

LOCATION 806 CAROLINA Ave CITY Crestonia
BETWEEN Park STREET & Central STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>127'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>10'</u>	<u>9-20-97</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>117'</u>			

ENTERS: 806 CAROLINA

BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 20 PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY EP


MAIN-SIZE 2" C.I. _____ BARE STEEL ✓ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1957

DEPTH: 2 FT. 6 IN. LOCATION _____

"A" P/S READING 0.5 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:

NO Anode Installed, Bare main to be Retired & Replaced



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY