

LOCATION 806 CAROLINA Ave. CITY GASTONIA
BETWEEN CENTRAL Ave. STREET & EDGEFIELD STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>- 0 -</u>	<u>3/7/98</u>	<u>Tied over</u>	<u>140' 3/4 PLASTIC</u>
MAIN TO PROP. LINE					<u>to New</u>	<u>2" PLASTIC</u>
PROP. LINE TO BLDG.					<u>GAJ Main</u>	

ENTERS: 806 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 255' W of C of Central Ave.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998
DEPTH: 4 FT. 0 IN. LOCATION 17' N of C of CAROLINA Ave.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:
- Tie Over -



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

ENG. DEPT. USE ONLY