

LOCATION 820 CAROLINA AveCITY GASTONBETWEEN Townsend Ave

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>77'</u>			
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>5'</u>		<u>3-</u>	<u>5-58</u>
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>72</u>			

ENTERS: 820BRANCHED INTO: -

TAP SIZE: <u>3/4</u>	PRESSURE <u>60</u> PSI	INCHES W C	LOCATION
----------------------	------------------------	------------	----------


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS BY SE

MAIN-SIZE <u>2"</u>	C.I. <u> </u>	BARE STEEL <u> </u>	COATED STEEL <u> </u>	PLASTIC <u> </u>	YEAR INSTALLED <u>1998</u>
---------------------	--------------------	--------------------------	----------------------------	-----------------------	----------------------------

DEPTH: FT IN LOCATION

"A" P/S READING <u>PL</u>	TOTAL ANODES 1# <u> </u> 17# <u> </u>	L.R. # <u> </u>
---------------------------	---	----------------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Rise</u>	<u>PL</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY