

LOCATION 602 CAROLINA CR.CITY GASTONIABETWEEN S. NEW HOPE ROADSTREET & AND CENTER LINE OF CAROLINA CR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>PL</u>	<u>118'</u>	<u>6-24-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>PL</u>	<u>8'</u>	<u>6-24-97</u>		
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>PL</u>	<u>110'</u>	<u>6-24-97</u>		

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 1,143' EAST OF CENTER  
OF S. NEW HOPE RD.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By D. MYERS

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3' Ft. \_\_\_\_\_ In. LOCATION 46' SOUTH OF CENTER OF CAROLINA CIRCLE

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY