

LOCATION 1616 CAROLINA CIRCLE

CITY GASTONIA

BETWEEN S. NEW HOPE RD

STREET AND END OF MAIN ON CAROLINA CIR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PL	106'	6/24/97		
MAIN TO PROP. LINE	3/4"	PL	8'	6/24/97		
PROP. LINE TO BLDG.	3/4"	PL	98'	6/24/97		

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 P.S.I. INCHES W.C. LOCATION 1187' EAST OF

CENTER LINE OF S NEW HOPE RD


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By D. MYERS

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3' Ft. In. LOCATION 45' SOUTH OF CENTER LINE ON CAROLINA CIRCLE

"A" P/S READING TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY