

LOCATION 108 Carpenter St. CITY GASTONIA  
BETWEEN Warren St. STREET & Dead End. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>85'</u>	<u>11-3-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>40'</u>			

ENTERS: 108 Carpenter St. BRANCHED INTO: 108 Carpenter St.  
TAP SIZE: 3/4 STRAIGHT P. TEE PRESSURE 60 P.S.I. INCHES W.C. LOCATION 403' E of C of Warren St.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL  
Service MAIN SIZE #4 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1995  
DEPTH: 2 Ft. 0 In. LOCATION 31' N of C of Carpenter St.

"A" P/S READING PLASTIC TOTAL ANODES 1# 17 # 1 L.R. # 566933

REMARKS: SPLIT SERVICE



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY