

LOCATION 109 Carpenter ST CITY Castonia  
BETWEEN WARREN ST STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>87'</u>	<u>6-26-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>83'</u>			

ENTERS: 109 BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 386' S. of center of  
WARREN ST.


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By S. Huffstake

MAIN-SIZE 2' C.I.      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION 13' W. of center of Carpenter St.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 308840

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY