


LOCATION 205 Carpenter St.CITY BARTONIABETWEEN STREET & Dead End. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>76'</u>	<u>6-13-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>66'</u>			

ENTERS: 205BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 600 PSI _____ INCHES W.C. LOCATION 596' E of Caf Warren St.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RLMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1995DEPTH: 3 FT. 6 IN. LOCATION 14' S of Caf Carpenter St"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 311127

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Rise Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY