

LOCATION 209 Carpenter St. CITY Gastonia
BETWEEN Warren St STREET & Dead End STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	78'	1-21-97		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	68'			

ENTERS: 209 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 600 PSI _____ INCHES W.C. LOCATION 759' S. of center of Warren St

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huttolett
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____
DEPTH: 3 FT 0 IN. LOCATION 13' W. of center of Carpenter St

"A" P/S READING P TOTAL ANODES 1# 0 17# 2 L.R. # 32436

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY