


LOCATION 214 Carpenter St.CITY GASTONIABETWEEN Warren St.STREET & Dead End.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	PLASTIC	92'	6-30-95		
MAIN TO PROP. LINE	3/4	PLASTIC	40'			
PROP. LINE TO BLDG.	3/4	PLASTIC	52'			

ENTERS: 214BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C.LOCATION 855' E of C of Warren St.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RLMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1995DEPTH: 3 Ft. 0 In. LOCATION 14' S of C of Carpenter St."A" P/S READING PLASTIC TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_ 313220

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser PLASTIC
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY