

LOCATION 114 CARRIE ELIZABETH CT CITY CASTONIA

BETWEEN LOWELL BETHESDA RD STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>160'</u>	<u>2-26-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>24'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>136'</u>			

ENTERS: 114 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI 0 INCHES W.C. LOCATION 388' E OF C OF

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY R.L. LOWELL BETHESDA RD

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1989

DEPTH: 3' FT 0 IN LOCATION 15' S OF C OF CARRIE ELIZABETH CT

"A" P/S READING PLASTIC TOTAL ANODES 1# 0 17# 0 L.R. # D125424

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>PLASTIC</u>
P/S Pipeline Lead - White Existing Main	E	<u>Rise</u>

ENG. DEPT. USE ONLY