

LOCATION 136 Carrie Elizabeth Ct CITY Castroville
BETWEEN Lowell-Bethesda Rd. STREET & Carl-de-Sue STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>116'</u>	<u>3-2-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>106'</u>			

ENTERS 136 BRANCHED INTO _____
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 1336'E. of center


of Lowell Bethesda/Car
PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION 16' S. of center of Carrie Elizabeth Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 155904

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	