

LOCATION 618 Carson Rd.CITY GastoniaBETWEEN Laurel Woods Dr.STREET & Justland Dr.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	104'	9-17-97		
MAIN TO PROP. LINE	3/4	P	10'			
PROP. LINE TO BLDG.	3/4	P	94'			

ENTERS: 618

BRANCHED INTO:

TAP SIZE. 1/2PRESSURE 60

PSI

INCHES W.C.

LOCATION 466' EAST ofLaurel Woods Dr.PRESSURE TEST: @ 100 PSI FOR 1/4 HRSBY [Signature]MAIN-SIZE 6"

C.I. _____


BARE STEEL _____

COATED STEEL ☒

PLASTIC _____

YEAR INSTALLED 1997DEPTH 3 FT 0 INLOCATION 15' South of Center of Carson Rd."A" P/S READING 1.0TOTAL ANODES 1# 0 17# 0L.R. # 624231

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY