

LOCATION 732 Carson Rd. CITY GASTONIA

BETWEEN Laurel Woods Dr STREET & Linwood Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	174'	9-18-98		
MAIN TO PROP LINE	3/4"	P	55'			
PROP. LINE TO BLDG.	3/4"	P	119'			

ENTERS: 732 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 729' E. of center of Justland Trl


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S. Huxestetter

MAIN-SIZE 6" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION 13' S. of center of Carson Rd.

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 LR # 2039637

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY