

LOCATION 2629 Castle Hill Rd. CITY GASTONIA

BETWEEN CASTLE HILL DR. STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	$\frac{3}{4}$	P	57	7.28.95		
MAIN TO PROP. LINE	"	"	2'			
PROP. LINE TO BLDG.	"	"	55			

ENTERS: 2629 CASTLE HILL BRANCHED INTO:

TAP SIZE:  $\frac{1}{2}$ " PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION W. Side of house


PRESSURE TEST: @ 100 psi For 14 Hrs. By RL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL / PLASTIC \_\_\_\_\_ YEAR INSTALLED 1980

DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION S. Side of Castle Hill

"A" P/S READING 85 TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY