

LOCATION 2638 Castle Hill Dr. CITY GASTONIA  
BETWEEN Castle Hill Rd. STREET & End of Culdesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>123'</u>	<u>1-26-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>47'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>76'</u>			

ENTERS: 2638 BRANCHED INTO: 0  
TAP SIZE: 3/8 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 91' W of Caf Castle Hill Rd.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BL  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1980

DEPTH. 3 FT. 6 IN. LOCATION 22' S of Caf Castle Hill Dr.


"A" P/S READING 1.6 TOTAL ANODES 1# 0 17# 0 L.R. # 034310

REMARKS:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Main - White

Service - Red

A

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG DEPT. USE ONLY