

LOCATION 2501 Chatterwood Dr. CITY Easton
BETWEEN Hoffman Rd STREET & Sordenside Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>133</u>	<u>10-25-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>		<u>13</u>			
PROP. LINE TO BLDG.	<u>3/4</u>		<u>120</u>			

ENTERS: 2501 BRANCHED INTO:
TAP SIZE: 3/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION White House


PRESSURE TEST: @ 100 psi For 44 Hrs. By Bennett

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1981

DEPTH: 2 Ft. 6 In. LOCATION 17' W of apt

"A" P/S READING 1030 TOTAL ANODES 1# _____ 17# _____ L.R. # 00472286

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY