


LOCATION	1612 CeCeLia DR.			CITY	GASTONIA		
BETWEEN	Flynn DR.		STREET &	Ridgewood DR		STREET	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED	
MAIN TO BLDG.	3/4"	Plastic	89'	1/4/95			
MAIN TO PROP. LINE	3/4"		12'				
PROP. LINE TO BLDG.	3/4"		22'				

ENTERS: 1612		BRANCHED INTO:	
TAP SIZE: 3/8"	PRESSURE 60 P.S.I.	INCHES W.C.	LOCATION South side of 1612

PRESSURE TEST: @ 100 psi For 4 Hrs. By DT			
MAIN-SIZE 2"	C.I. <input type="checkbox"/>	BARE STEEL <input type="checkbox"/>	COATED STEEL <input checked="" type="checkbox"/> PLASTIC <input type="checkbox"/>
DEPTH: 2 Ft. 6 In.	LOCATION East side of CeCeLia DR		

"A" P/S READING 1.40	TOTAL ANODES 1*0 17*0	L.R. # 572512
----------------------	-----------------------	---------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY