

LOCATION 2203 Cedar St

CITY Gastonia

BETWEEN Midway

STREET &amp; Fairway

STREET

|                     | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG.       | 3/4  | P    | 10.5'  | 2-27-95   |         |         |
| MAIN TO PROP. LINE  | 1"   | "    | 40'    |           |         |         |
| PROP. LINE TO BLDG. | 1"   | "    | 65'    |           |         |         |

ENTERS: 2203

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 85' E of C of Midway


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BC

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 Ft. In. LOCATION 13' S of C of Cedar

"A" P/S READING plastic TOTAL ANODES 1# 17# L.R. # 73571

REMARKS:



| Test Station                               |      |       |
|--|------|-------|
| Reading & Location                         | Lead | Volts |
| P/S Pipeline Lead - Red<br>New Service     | S R  | P     |
| P/S Pipeline Lead - White<br>Existing Main | E    |       |

ENG. DEPT. USE ONLY