

LOCATION 2209 Cedar StCITY GASTONIABETWEEN Midway

STREET &amp;

FAIRWAY

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PLASTIC	101'	10/11/94		
MAIN TO PROP. LINE	3/4"		38'			
PROP. LINE TO BLDG.	3/4"		63'			

ENTERS: 2209

BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION North side of 2209PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DTMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1993DEPTH: 3 Ft. 0 In. LOCATION West side of Cedar"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1\* 0 17\* 0 L.R. # 422535

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY