

LOCATION 2215 Cedar StCITY GastoniaBETWEEN Fairway

STREET &

Midway

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	64'	3-17-94		
MAIN TO PROP. LINE	1"	"	36'			
PROP. LINE TO BLDG.	1"	"	28			

ENTERS: 2215BRANCHED INTO: 0

TAP SIZE: <u>1/2</u>	PRESSURE <u>60</u> P.S.I.	INCHES W.C.	LOCATION <u>W. Side of 2215</u>
----------------------	---------------------------	-------------	---------------------------------

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BCMAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1994DEPTH: 3 Ft. In. LOCATION 13' W' of C of Fairway"A" P/S READING Plastic TOTAL ANODES 1* - 17* - L.R. # 87874

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY