

LOCATION 608 Cedar Grove Dr CITY Gastonia
 BETWEEN Darwood Circle STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>88'</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>	<u>2-29-00</u>		
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>83'</u>			

ENTERS 608 BRANCHED INTO 0

TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY EP

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH 4 FT 0 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# - 17# - LR # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	