

LOCATION 616 Cedar Grove Dr. CITY Castania
BETWEEN Oakwood Cir. STREET & Robinson Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>86'</u>	<u>8-2-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>76'</u>			

ENTERS 616 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 231' N of center of Oakwood Cir.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SK

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH 3 FT 0 IN LOCATION 12' E. of center of Cedar Grove Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 601310

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	