

LOCATION 3324 Chapel Stone Rd CITY Indianapolis

BETWEEN Old Providence STREET & Greenleaf STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>92</u>	<u>4-5-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>16</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>76</u>			

ENTERS: 3324 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Side of Bldg


PRESSURE TEST: @ 100 psi For 14 Hrs. By Donett

MAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL / PLASTIC _____ YEAR INSTALLED 1963

DEPTH: 2 Ft. 6 In. LOCATION 14'E of C&H

"A" P/S READING 1.80 TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY