

LOCATION 3706 Chapel Grove ~~School~~ Rd. CITY GASTON, N.C.
BETWEEN Hickory Creek STREET & BRANDYWINE STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>127</u>	<u>5-5-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>10</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>117</u>			

ENTERS: 3706 BRANCHED INTO:

TAP SIZE: ~~3/8~~ 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION E. Side Rd.


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By [Signature]

MAIN-SIZE 8" C.I. _____ BARE STEEL _____ COATED STEEL X PLASTIC _____ YEAR INSTALLED 1965

DEPTH: 3 Ft. 0 In. LOCATION _____

"A" P/S READING 1.8 TOTAL ANODES 1# — 17# — L.R. # 184361

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY