


LOCATION 48, 120, 116, 112 Charwood DriveCITY GASTON, NCBETWEEN RidgeSTREET & Charwood

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>22'</u>	<u>TIED OVER</u> <u>3-31-95</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 120BRANCHED INTO: 48, 116, 112TAP SIZE: 3/8PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION 88' W OF US 321PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Marty ParkerMAIN-SIZE 8" C.I. _____ BARE STEEL _____ COATED STEEL X PLASTIC _____ YEAR INSTALLED 1994DEPTH: 3 Ft. 0 In. LOCATION 402' N OF Ridge"A" P/S READING 1.5 TOTAL ANODES 1# 2 17# L.R. # _____REMARKS: READINGS FROM 120 + 116 1.5 + ALL 3/4" CWALL 3/4" CW BONDED SOLID - WIRE TIED OFF AT 3/4" TIE AT TIE IN

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>.78"</u> CW MATN
P/S Pipeline Lead - White Existing Main	E	<u>1.5 EXIST</u> <u>3/4" SERVICES</u> CW

ENG. DEPT. USE ONLY