

LOCATION 3515 + 3519 S. York Rd. (120 CHARLWOOD DR.) CITY GASTONIA

BETWEEN N/A DAWN Ave. STREET & Little Mt. Rd. STREET

	SIZE	TYPE	3515 LENGTH	3519	INSTALLED	3515 RETIRED	Retired 3519
MAIN TO BLDG.	3/4	Plastic	94'	35'	3-25-95	125' Existing	35' 3/4"
MAIN TO PROP. LINE	3/4	Plastic	10'	15'		3/4 inch	GFW Pipe on
PROP. LINE TO BLDG.	3/4	Plastic	84'	20'		GFW Pipe	3519

ENTERS: 3515 BRANCHED INTO: 3519

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 405' N of C of Little Mt. Rd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 8" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1994

DEPTH: 4 Ft. 0 In. LOCATION 37' W of C of S. York Rd. 321 South.

"A" P/S READING 85 to be Put on Reck-T-Fier TOTAL ANODES 1# 17# L.R. #

REMARKS: Split Service's.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser's Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY

3515 Plastic
3519 Risers