

LOCATION 4343 Chelsea Way CITY GASTONIA
BETWEEN BAYWOOD CT. STREET & Chelsea Way STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>88'</u>	<u>10-27-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>43</u>			

ENTERS: 4343 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 150' S of C of Chelsea Way


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BL

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1970

DEPTH: 3 Ft. 0 In. LOCATION 13'E of C of Gaston Day School Rd.

"A" P/S READING 1.0 TOTAL ANODES 1* 17* L.R. # 546924

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY