

LOCATION 203 N. Cherry St CITY GAST.  
BETWEEN AIR LINE STREET & RANKIN STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	50'		4-2	-96
MAIN TO PROP. LINE	"	"	4'			
PROP. LINE TO BLDG.	"	"	46'			

ENTERS: 203 N. Cherry St. BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 P.S.I. INCHES W.C. LOCATION N. of 203

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GIK  
MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 96  
DEPTH: 3 Ft. In. LOCATION W. Side of N. Cherry

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	7
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY