

LOCATION 215 & 217 N. CHERRY CITY Gast.  
BETWEEN AIRLINE STREET & RANKIN STREET


	SIZE	TYPE	217 LENGTH 215	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	47' 12'		4 - 9	- 96
MAIN TO PROP. LINE	"	"	4' 0			
PROP. LINE TO BLDG.	"	"	43' 12'			

ENTERS: 217 N. CHERRY BRANCHED INTO: 215 N. CHERRY  
TAP SIZE: 3/4" PRESSURE 100 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION S. of 217  
N. " 215

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GK  
MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 96  
DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION W. Side of N. Cherry

"A" P/S READING P TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>7</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY