

LOCATION

211 N. CHESTER

CITY

GAST.

BETWEEN

YORK RD.

STREET &amp;

BOYCE

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	94'		3.5.	96
MAIN TO PROP. LINE	"	"	3'			
PROP. LINE TO BLDG.	"	"	91'			

ENTERS:

211 N. Chester

BRANCHED INTO:

TAP SIZE:

1/2

PRESSURE

100

P.S.I.

INCHES W.C.

LOCATION

W. side of Business

PRESSURE TEST: @

100

psi

For

1 1/2

Hrs.

By

GIL

MAIN-SIZE

4

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

96

DEPTH:

3 Ft.

In.

LOCATION

E side of N Boyce

"A" P/S READING

P


TOTAL ANODES

1#

17#

L.R. #

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY