

LOCATION 1629 N. Chester St. CITY GASTONIA  
BETWEEN Radio St. STREET & Windy Hill STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>245'</u>	<u>2-7-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>88'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>157'</u>			

ENTERS: 1629 BRANCHED INTO: 0  
TAP SIZE: 3/8 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 30' S of C of Radio St.

PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY RL  
MAIN-SIZE 6" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1964  
DEPTH: 3 FT. 0 IN. LOCATION 45' E of C of N. Chester St.

"A" P/S READING 1.7 TOTAL ANODES 1# 0 17# 0 L.R. # 065903

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY