

LOCATION 2106 N. Chester St (BLG. A) CITY GASTONIA

BETWEEN Rankin Lake Rd STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>278'</u>	<u>8-14-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>278'</u>			

ENTERS: 2106 BLG. A BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 196' E of center of N. Chester St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstetler

MAIN-SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH: 2 FT. 0 IN. LOCATION 168' N. of center of

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 2005015

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY