

LOCATION 2347 N. Chester Precision Machine CITY Gastonia
BETWEEN Tub. P STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>28'</u>	<u>Relocated</u>		
MAIN TO PROP. LINE				<u>5-17-95</u>		
PROP. LINE TO BLDG.						


ENTERS: 2347 BRANCHED INTO: 2347
TAP SIZE: 3/4 Sec. PRESSURE 60 P.S.I. INCHES W.C. LOCATION

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP
MAIN SIZE 3/4 C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1982
DEPTH: 2 Ft. 6 In. LOCATION

"A" P/S READING 1.2 TOTAL ANODES 1* Q17* Q L.R. #

REMARKS:
Tracer wire on plastic riser is test point on EXT 3/4
plw pipe

Test Box Not Feasible in parking lot



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY