

LOCATION 2415 N. Chester St. STE-A CITY CANTONIA
BETWEEN Talip Dr. STREET & Orier Beam Blvd. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>185'</u>	<u>6-9-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>0'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>185'</u>			

ENTERS: 2415 BRANCHED INTO: 2415 STE-A
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 655' N of C of Talip Dr

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
PIPE SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1965
DEPTH: 2 FT. 0 IN. LOCATION 150' W of C of 45.321

"A" P/S READING 1.5 TOTAL ANODES 1# 0 17# 0 L.R. # 359643

REMARKS: split service



Main - White

Service - Red

A

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	E	<u>PLASTIC</u>

ENG. DEPT. USE ONLY