

LOCATION 2433 N Chester st (321 N) CITY BASTONIA
BETWEEN Tulip DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4'</u>	<u>Plastic</u>	<u>154'</u>			
MAIN TO PROP. LINE	<u>3/4'</u>		<u>43'</u>			
PROP. LINE TO BLDG.	<u>3/4'</u>		<u>111'</u>			

ENTERS: 2433 BRANCHED INTO:
TAP SIZE: 3/8" PRESSURE 60 PSI INCHES W.C. LOCATION N side of 2433


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY DT

MAIN-SIZE 6" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1964

DEPTH: 4' FT. IN. LOCATION West of Center Line of N Chester st

"A" P/S READING 1.30 TOTAL ANODES 1# 0 17# 0 I.R. # 034307

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY